


KENDRIYA VIDYALAYA NO 02 SOHNA ROAD, GURGAON

↳ T-24 Sub

It is certified that T-55 & T-56 building are of old vintage buildings and no major cracks are found on building. However to get exact structure stability of the buildings a structural audit may please be carried out by specialized structural consultancy firm.



JE (Civ)


(Sumit Kumar)
AE (Civ)
AGE B/R (AF) Gurgaon

COUNTERSIGNED

Station : Gurgaon

Dated : Jun 2021


(Shrenik M Kadam)
Lt Col
GE (AF) - Gurgaon